



(1) Water enters the purifier and flows into the annular space between the quartz sleeve and the chamber wall.

(2) Within the chamber, water is exposed to intense germicidal ultraviolet radiation.

(3) Transformer with LED indicator light provides visual indication of germicidal lamp operation.

(4) Water leaving the purifier is instantly ready for use.